

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-0075:181 Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653
Contact: Brian Reynolds (203) 484-1200

DESIGN: Model FIRE COMMAND 25/50 and *25/50X single zone voice evacuation/emergency message pane. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

Master Command Board	Master Unit Circuit Board
FC-PSM	Power Supply Module
FC-AAM-25, *FCAAM25X	Audio Amplifier Module
FC-XRM-70	Transformer Module
FC-LPS	Local Playback Speakers

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

APPROVAL: Listed as voice communication systems for use with separately listed compatible fire alarm control units to provide emergency voice evacuation signals.

NOTE: For Alarm Verification Feature, the maximum Retard/Rest/Restart shall be adjusted to 30 seconds or less.

*Revised 06-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 26, 2002**

Listing Expires **June 30, 2003**

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**